

**PROPOSAL FOR CODE CHANGE**

State Form 41186 (R2 / 1-92)

RETURN TO: INDIANA DEPARTMENT OF
FIRE AND BUILDING SERVICES
402 W. Washington St., Rm 246
Indianapolis, IN 46204**OFFICE USE ONLY 6-16-****09****ITEM NUMBER****CHANGE NUMBER****38-09 R**

INSTRUCTIONS: Only TYPED copy accepted.

KEY: ~~Dashed line through material to be deleted~~; underline or **bold face** material to be added.

Use second sheet for any material requiring more space.

| | | |
|---|--|-------------------------|
| Code title: Indiana Residential Code | | Edition: 2009 |
| Section number and title: R311.7.7.3, grip size | | Sheet: 1 of 1 |
| Proponent: Craig Wagner/IABO | Title: Code Committee Member | |

| | |
|---|--|
| Address: 220 W Van Buren St, Ste 204, Columbia City, IN 46725 | Telephone number: (260) 248-3111 |
|---|--|

PROPOSED CODE CHANGE (check one)☒ Change to read as follows. Add to read as follows. Delete and substitute as follows. Delete without substitution.

Change R311.7.7.3, Item 2., fourth sentence as follows: ...to a maximum ~~2³/₄ inches (70 mm)~~ 2⁷/₈ inches (72mm).

REASON

This proposal allows the use of several handrails that have been used successfully in Indiana.

Revision: I had 2" listed as the original text, it should be 2³/₄".

Fiscal impact: there is no increase in the cost of construction.

REVIEW RECOMMENDATION

Approve

Disapprove

Approve as amended

Further study